

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

SACRED SOULS SCHOOL
KAURIWARA (SARDULGARH)


No.: DWTL/MNS/2526/00328 Dated : 27/02/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 633 Dated: 25/02/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 25/02/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Mansa



TC-11386

TEST REPORT						
Name & Address of Customer : SACRED SOULS SCHOOL KAURIWARA (SARDULGARH)			Customer Reference No.		No : 633 Dated : 25/02/2026	
			Sample Submitted by		MR BHUSHAN KUMAR	
			Date of Sample Receipt		25/02/2026	
			Analysis Starting Date		26/02/2026	
			Analysis completion Date		27/02/2026	
Discipline : Chemical Testing			Group: Water			
ULR No.:	TC11386260000048F		Sample Type :		Water	
Test Report No.:	DWTL/MNS/2526/00328		Date of Issue :		27/02/2026	
Registration no.:	DWTL/MNS/REG2526/03593		Condition of Sample :		Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Transparent Plastic Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		NA / NA	
Village :	Kauri Wara		Habitation :		Kauri Wara	
Block:	Sardulgarh		District :		Mansa	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.01@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	AGREEABLE	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	49	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	36	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	18	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	6.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	0.48	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	11.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

----- End of the Test Report -----