

**DISTRICT WATER TESTING LABORATORY**  
(TECH. MISSION)

WATER SUPPLY AND SANITATION DEPTT. PUNJAB

Water Works Jawaharke, Division No. 1, Mansa

**ANALYSIS REPORT FOR PHYSICAL AND CHEMICAL TEST**  
EXAMINATION OF WATER SAMPLE

email:- dwltmansa@gmail.com

**PARTICULARS OF SAMPLE**

1. Name	SACRED SOULS' SCHOOL (REF.98) - KAURIWAL		
2. Block :-	SARDHULGARH	6. If Whether water chlorination or Not:-	.....--
3. District :-	MANSA	7. Date of collection :-	10-05-21
4. Source of sample	RO	8. Name and designation of Smt. Upasana Sabharwal	
Spring level (mt)/ft :-		person collecting sample :-	Principal
Depth level (mt) :-	.....	9. Date of receipt :-	10-05-21
		10. Date of commencing examination :-	12-05-21

**TEST RESULT**

		Desirable Limit	Permissible Limit
Colour(Unit on Pt-Co scale)	colour less	5.0	25
Taste and Odour(Qualitative)	ordinary		
Total Alkanity(CaCO <sub>3</sub> )mg/l	26	200	600
Calcium(Ca)mg/l	-	75	200
Chlorides(Cl)mg/l	18	250	1000
Fluorides(F)mg/l	0.30	1.00	1.50
Total Hardness(CaCO <sub>3</sub> )mg/l	38	200	600
Iron(Fe)mg/l	0.04	0.3	1.00
Magnesium(Mg)mg/l	-	30	75
PH	6.68	6.5-8.5	8.5
Nitrates(NO <sub>2</sub> )mg/l	04	15	45
Sulphates(SO <sub>4</sub> )mg/l	-	200	400
Total Dissolved Solids(mg/l)	102	500	2000
Turbidity(JTU)	1.02	2.5	10
Residual Chlorine mg/l	-	0.2	

**Bacteriological Test****Coliform Organism MPN/100 m Nil**

## REMARKS :---

*G. Singh*  
Chemist  
Distt. Water Testing Laboratory  
W/S & Sanitation Department  
Mansa

1. This report is not for legal purpose.
2. Whole sample consumed in testing
3. Sample not drawn by us unless otherwise stated.



ਦਫ਼ਤਰ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਜਲ ਸਪਲਾਈ ਅਤੇ ਸੈਨੀਟੇਸ਼ਨ ਉਪ ਮੰਡਲ ਸਰਦੂਲਗੜ੍ਹ

Email: sdesdgrws@gmail.com


Ph. No.: 01659-250986


Letter No 316

Date 18-05-2021

**CERTIFICATE REGARDING SAFE DRINKING WATER AND SANITARY CONDITION.**

Certified that **Sacred Souls School Kauriwara**, Block Sardulgarh, District Mansa (PUNJAB) was inspected by **Sh. Rachhpal Singh S.D.E. Water Supply & Sanitation Department Sub Division Sardulgarh** and found that **Sacred Souls School Kauriwara**, Block Sardulgarh District Mansa (PUNJAB) has safe Drinking Water Facilities for the Students and Members of the Institution as per Report No – **DWTL/MNS/0021/21-22 District Water Testing Laboratory Mansa** and is maintaining the Hygienic Sanitation conditions in the School Building and the Campus as par the norms .(Valid up to 31/03/2022)

  
Sub Divisional Engineer  
W/S & Sanitation Sub Division  
Sardulgarh

  
13/5/2021

## To Whom It May Concern

No./Health/Hyg/SDG/2021=105

Date 20/04/2021

It is to inform you, that, **SACRED SOULS' SCHOOL, KAURIWARA, SARDULGARH** was inspected on **19/04/2021** The Sanitary and hygienic conditions in the School/Factory/Industry/Canteen/Hotel/Bars/Godown/is satisfactory.

This certificated is valid for one year from the date of issue.

  
Dy. Civil Surgeon (Health)

Sardulgarh 